

KERALA STATE NIRMITHI KENDRA



NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695 013
PHONE No. : 2362229

No. 16986

No: T5/922/2021-22/RNK-TVPM

Date: 26.07.2023

Ref: Your request letter

Testing of: Concrete cube supplied for testing compressive strength

Cash Remittance: Amount ₹472/- Invoice No. 3855 Date 25.07.2023

To
Mr. Jose
Architect
Thokarappamb

TEST RESULTS

1. Identification of the cube : 1
2. Mix : M₂₅
3. Date of casting : 12.07.2023
4. Maximum load taken : 550KN
5. Compressive strength : 28.89 N/mm²

Test conducted by

Signature:

Verified by: Shane S, Overseer

Signature: Shane

COUNTER SIGNED AND ISSUED

Office Seal

For DIRECTOR

KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY



CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695 013
PHONE No. : 2362229

No. **16987**

No: T5/922/2021-22/RNK-TVPM

Date: 26.07.2023

Ref: Your request letter dtd 26.07.2023

Testing of: 6 nos of blocks (8" srb - 3 nos & 6" srb 3 nos) solid concrete blocks supplied for testing compressive strength

Cash Remittance:	Amount	Invoice No.	Date
------------------	--------	-------------	------

To
Mr. Dixon Raj Devanajam
Roadvila Verdu,
Moyyanadu Po, Kollam

TEST RESULTS

Identification of the Block	Size of the Block (mm)	Maximum load taken (kN)	Compressive Strength (N/mm ²)
8" srb	400 x 200 x 200	466	5.83
8" srb	400 x 200 x 200	466	5.83
8" srb	400 x 200 x 200	468	5.85
6" srb	400 x 150 x 200	330	5.50
6" srb	400 x 150 x 200	334	5.57
6" srb	400 x 150 x 200	332	5.53

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED

Office Seal

For DIRECTOR



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695 013
PHONE No. : 2362229

No: 6988

No: T5/922/2021-22/RNK-TVPM

Date: 26.07.2023

Ref: Your request letter dtd 26.07.2023

Testing of: 3 nos of 4" solid concrete blocks supplied for testing compressive strength

Cash Remittance:	Amount	Invoice No.	Date
To	Mr. Dixon Raj Devarajan		

TEST RESULTS			
Identification of the Blocks	Size of the Block (mm)	Maximum load taken (kN)	Compressive Strength (N/mm ²)
4" SCB	400 x 100 x 200	204	5.10
4" SCB	400 x 100 x 200	206	5.15
4" SCB	400 x 100 x 200	202	5.05

Test conducted by:


Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED

Office Seal


For DIRECTOR