



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17025

Date:08.08.2023

No. T5/922/2021-22/RNK-TVPM

Ref:- Your request letter No.AE/LSGD/PGD/QIt-02/2023-24 dtd.08.08.2023

Testing of: 3 nos of concrete cube supplied for testing compressive strength.

Project Name : Annual Plan - 2021-22 - Govt.LPS Bharathanoor

CASH REMITTANCE DETAILS		
Amount: 1416/-	Invoice No. 3933	Invoice Date: 08.08.2023

To

The Assistant Engineer  
LSGD Section,  
Pangode Grama Panchayath.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
1	M <sub>20</sub>	11.07.2023	640	28.44
2	M <sub>20</sub>	11.07.2023	650	28.89
3	M <sub>20</sub>	11.07.2023	600	26.67

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer