



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17046

Date:16.08.2023

Ref:- Your request letter dtd.16.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.
Pile Cap.

Project:-

Amount:1416/-

Invoice No. 3973

Invoice Date: 16.08.2023

To M/SGD Constructions.
Contractors.

Engineers &

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	09.08.2023	530	23.56
2	M ₂₅	09.08.2023	570	25.33
3	M ₂₅	09.08.2023	550	24.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17047

Date:16.08.2023

Ref:- Your request letter dtd.16.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:-

Construction of foundation of sales building of petrol pump at Killi, Kattakkada.

Amount:1416/-

Invoice No. 3979

Invoice Date: 16.08.2023

To Project Engineer
Reliance BP Mobility Ltd.

EPSILON,

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	09.08.2023	410	18.22
2	M ₂₅	09.08.2023	400	17.78
3	M ₂₅	09.08.2023	400	17.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17048

Date:16.08.2023

Ref:- Your request letter No. QA/SFS/008/57 dtd.16.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.
SFS AMBER BLUE BLOCK.

Project:-

Amount:1416/-	Invoice No. 3980	Invoice Date: 16.08.2023
---------------	------------------	--------------------------

To M/sSkyline Foundation and Structures(P) Ltd

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₃₀	08.08.2023	620	27.56
2	M ₃₀	08.08.2023	680	30.22
3	M ₃₀	08.08.2023	620	27.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17049

Date:16.08.2023

Ref:- Your request letter No. QA/SFS/008/58 dtd.16.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:-

SFS Amber Green Block.

Amount:1416/-	Invoice No. 3980	Invoice Date: 16.08.2023
---------------	------------------	--------------------------

To M/Sskyline Foundation and Structures(P) Ltd

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₄₅	07.08.2023	850	37.78
2	M ₄₅	07.08.2023	930	41.33
3	M ₄₅	07.08.2023	810	36.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17050

Date:16.08.2023

Ref:- Your request letter dtd.16.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:-

Ramachandran Project at Thirumala.

Amount:1416/-	Invoice No. 3981	Invoice Date: 16.08.2023
---------------	------------------	--------------------------

To M/S Prime Bricks

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
F-S	M ₃₀	08.08.2023	480	21.33
F-S	M ₃₀	08.08.2023	550	24.44
F-S	M ₃₀	08.08.2023	480	21.33

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer