



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17051

Date:17.08.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:-

Pile cap phase - 2

Amount:944/-	Invoice No. 3984	Invoice Date: 17.08.2023
--------------	------------------	--------------------------

To Mr.Jose  
Thakaraparambu site.

Architect,

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
1	M <sub>25</sub>	10.08.2023	560	24.89
2	M <sub>25</sub>	10.08.2023	500	22.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17052

Date:17.08.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.  
KLML 9041

Site ID:

Amount:1416/-	Invoice No. 3986	Invoice Date: 17.08.2023
---------------	------------------	--------------------------

To M/S Reliance Jio  
Building.

Geethanjali

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
1	M <sub>20</sub>	04.08.2023	460	20.44
2	M <sub>20</sub>	04.08.2023	470	20.89
3	M <sub>20</sub>	04.08.2023	440	19.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17053

Date:17.08.2023

Ref:- Your request letter No.QA/SFS/008/59 dtd.17.08.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:-

SFS Amber Blue Block - Seventh floor column.

Amount:1416/-	Invoice No. 3989	Invoice Date: 17.08.2023
---------------	------------------	--------------------------

To M/Sskyline Foundation and Structures(P) Ltd

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
1	M <sub>45</sub>	10.08.2023	900	40.00
2	M <sub>45</sub>	10.08.2023	880	39.11
3	M <sub>45</sub>	10.08.2023	900	40.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17054

Date:17.08.2023

Ref:- Your request letter dtd.17.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.  
Ramachandran Commercial Project at Thirumala.

Project:-

Amount:1416/-	Invoice No. 3990	Invoice Date: 17.08.2023
---------------	------------------	--------------------------

To M/S Prime Bricks

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
F-S	M <sub>30</sub>	20.07.2023	800	35.56
F-S	M <sub>30</sub>	20.07.2023	880	39.11
F-S	M <sub>30</sub>	20.07.2023	900	40.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer