



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17069

Date: 21.08.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.  
I-KL-VASW-ENB-0002 Vizhinjam 2

Project:

Amount:1416/-	Invoice No. 4008	Invoice Date: 21.08.2023
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrasrtuctures (P)Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
VASW-0002	M <sub>20</sub>	08.08.2023	520	23.11
VASW-0002	M <sub>20</sub>	08.08.2023	500	22.22
VASW-0002	M <sub>20</sub>	08.08.2023	520	23.11

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



## KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17070

Date: 21.08.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.  
I-KL-KJML-ENB-9002 Manaveli Jn.

Project:

Amount:1416/-	Invoice No. 4008	Invoice Date: 21.08.2023
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrasrtuctures (P)Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
KJML-9002	M <sub>20</sub>	20.07.2023	680	30.22
KJML-9002	M <sub>20</sub>	20.07.2023	600	26.67
KJML-9002	M <sub>20</sub>	20.07.2023	580	25.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17071

Date: 21.08.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:

I-KL-KJML-ENB-9002 Manaveli Jn.

Amount:1416/-	Invoice No. 4008	Invoice Date: 21.08.2023
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrasrtuctures (P)Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
KJML-9002	M <sub>20</sub>	21.07.2023	600	26.67
KJML-9002	M <sub>20</sub>	21.07.2023	500	22.22
KJML-9002	M <sub>20</sub>	21.07.2023	560	24.89

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



## KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17072

Date: 21.08.2023

Ref:- Your request letter SCTL/TECH/1286/2020/AM(CIVIL)/7622

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:

Development of Chalai Warehouse & Commercial Complex. Description: site trial mix.

Amount: 1416/-	Invoice No. 4018	Invoice Date: 21.08.2023
----------------	------------------	--------------------------

To The Senior Manager (PMM)  
City Thiruvananthapuram Limited.

Smart

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
I	M <sub>30</sub>	18.08.2023	530	23.56
II	M <sub>30</sub>	18.08.2023	400	17.78
III	M <sub>30</sub>	18.08.2023	500	22.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer