



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
REGIONAL OFFICE
KODUMBU, PALAKKAD
PHONE No. 04912571492

No. Tech/108/13/RNK.P

Date: 14/8/2023

Ref:- 2nos of concrete cubes supplied for testing compressive strength

Testing of: 7th day

CASH REMITTANCE DETAILS



Amount ₹	944.00	Invoice No. 2434
----------	--------	------------------

To Mr.Mubarak Ali
Kanjikode

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
M20 (5/08/2023)	M20	5/8/2023	210	9.33
"	"	"	180	8.00

Test conducted by: Jyothish.ks
Verified by: Santhandasan

Signature: 
Signature: 

COUNTER SIGNED AND ISSUED



Office Seal



GIRISH. M.
Regional Engineer
Kerala State Nirmithi Kendra
Regional Centre, Palakkad