



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

REGIONAL OFFICE

KODUMBU, PALAKKAD

PHONE No. 04912571492

No. Tech/108/13/RNK.P

Date: 24/7/2023

Ref:- 6nos of concrete cubes supplied for testing compressive strength
on 28th day-main slab

Testing of: Renovation of college canteen construction cum co-operative store and post
office building at govt arts and science college pathiripala palakkad

CASH REMITTANCE DETAILS

Amount ₹	2832.00	Invoice No. 2433
----------	---------	------------------

To Mr.Abdul Rassak V A
Velliyath house, kuzhivellipady, edathala(p.o), aluva


TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
M20 (26/06/2023)	M20	26/06/2023	510	22.66
"	"	"	510	22.66
"	"	"	530	23.55
"	"	"	550	24.44
"	"	"	540	24.00
"	"	"	550	24.44

Test conducted by: Jyothish.ks

Signature: 

Verified by: Santhandasan

Signature: 

COUNTER SIGNED AND ISSUED



Office Seal



GIRISH. M.
Regional Engineer
Kerala State Nirmithi Kendra
Regional Centre, Palakkad