



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17190

No. T5/922/2021-22/RNK-TVPM

Date: 23.09.2023

Ref:- Your request letter dtd 23.09.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Motel Aaram, Nedumangad - Tank concrete

Amount:1416/-	Invoice No. 4149	Invoice Date: 23.09.2023
---------------	------------------	--------------------------

To The Regional Engineers

Kerala State Nirmithi Kendra,Vattiyoorkavu.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	15.09.2023	500	22.22
2	M ₂₅	15.09.2023	500	22.22
3	M ₂₅	15.09.2023	520	23.11

Test conducted by:

Verified by:

Signature:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17191
Date: 23.09.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: I-KL-NNKR-ENB-9204, Mulloor.

Amount:1416/-	Invoice No. 4149	Invoice Date: 23.09.2023
---------------	------------------	--------------------------

To M/s Karakkattil Projects and Infrastrucure Pvt.Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₂₅	15.09.2023	500	22.22
2	M ₂₅	15.09.2023	500	22.22
3	M ₂₅	15.09.2023	520	23.11

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer