



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17207

No. T5/922/2021-22/RNK-TVPM

Date: 04.10.2023

Ref:- Your request letter 68/AE/LSGD/PKML/2023 dtd.04.10.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Construction of Govt,LP School Pappala in Pazhayakunnummel GP.

Amount:1416/-

Invoice No. 4181

Invoice Date: 04.10.2023

To The Assistant Engineer

LID & EW Section, Pazhayakunnummel GP

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	M ₂₅	08.09.2023	590	26.22
II	M ₂₅	08.09.2023	850	37.78
III	M ₂₅	08.09.2023	580	25.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17208

No. T5/922/2021-22/RNK-TVPM

Date: 04.10.2023

Ref:- Your request letter No. SCTL/TECH/1286/2020/AM(CIVIL)/7902 dtd.03.10.2023
Testing of: 3 no's of concrete cube supplied for testing compressive strength.
Project: Chali Warehouse .

Amount:1416/-	Invoice No. 4180	Invoice Date: 04.10.2023
---------------	------------------	--------------------------

To The Senior Manager(PMM)
Smart City Thiruvananthapuram LTD.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	M ₂₅	05.09.2023	880	39.11
II	M ₂₅	05.09.2023	860	38.22
III	M ₂₅	05.09.2023	900	40.00

Test conducted by:
Verified by:

Signature:
Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer