



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17148

No. T5/922/2021-22/RNK-TVPM

Date: 12.09.2023

Ref:- Your request letter No.QA/SFS/008/74 dtd.12.09.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: SFS AMBER Green Block - Sixth floor slab and beam.

Amount:1416/-	Invoice No. 4099	Invoice Date: 12.09.2023
---------------	------------------	--------------------------

To M/s Skyline Foundation & Structuers(P) Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₃₀	14.08.2023	1090	48.44
2	M ₃₀	14.08.2023	940	41.78
3	M ₃₀	14.08.2023	1220	54.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17149

No. T5/922/2021-22/RNK-TVPM

Date: 13.09.2023

Ref:- Your request letter

Testing of: Concrete cube supplied for testing compressive strength.

Project:

Plinth Beam Phase 2.

Amount:472/-	Invoice No. 4106	Invoice Date: 13.09.2023
--------------	------------------	--------------------------

To Jose

Architect, Thakaraparamb site.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	16.08.2023	590	26.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17150

No. T5/922/2021-22/RNK-TVPM

Date: 13.09.2023

Ref:- Your request letter

Testing of: Concrete cube supplied for testing compressive strength.

Project:

Plinth Beam Phase 2.

Amount:472/-	Invoice No. 4106	Invoice Date: 13.09.2023
--------------	------------------	--------------------------

To Jose

Architect, Thakaraparamb site.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	16.08.2023	630	28.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17151

No. T5/922/2021-22/RNK-TVPM

Date: 13.09.2023

Ref:- Your request letter dtd.13.09.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Artect Panorama - concrete:Ultratech RMC.

Amount:1416/-	Invoice No. 4108	Invoice Date: 13.09.2023
---------------	------------------	--------------------------

To M/s GJ BUILDERS & REALTORS.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₆₀	14.08.2023	1380	61.33
2	M ₆₀	14.08.2023	1400	62.22
3	M ₆₀	14.08.2023	1480	65.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17152

No. T5/922/2021-22/RNK-TVPM

Date: 13.09.2023

Ref:- Your request letter No.SCTL/PRJ/241/2019-IT(TSCCC)/17726 dtd.07.09.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Traffic & safety command control centre(TSCCC) and adaptive traffic control system (ATCS) -Pedestrial foundation.

Amount:1416/-	Invoice No. 4109	Invoice Date: 13.09.2023
---------------	------------------	--------------------------

To M/s Smartcity Thiruvananthapuram Limited.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	11.08.2023	590	26.22
2	M ₂₅	11.08.2023	910	40.44
3	M ₂₅	11.08.2023	1000	44.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer