



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17192

No. T5/922/2021-22/RNK-TVPM

Date: 25.09.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Livedus Project at Thonnakkal.

Amount:1416/-	Invoice No. 4151	Invoice Date: 25.09.2023
---------------	------------------	--------------------------

To Mr. Amjith Kunju
Puthumanel Building North Pada,
Kollam.

Karunagapally,

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
4	M ₃₀	17.09.2023	560	24.89
5	M ₃₀	15.09.2023	450	20.00
6	M ₃₀	15.09.2023	420	18.67

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17193
Date: 25.09.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Construction of Mini Indoor Stadium at Meenara Manickal GP,
Thiruvananthapuram.

Amount:1416/-	Invoice No. 4152	Invoice Date: 25.09.2023
---------------	------------------	--------------------------

To The Chief Engineer
Sports Foundation ,Thiruvananthapuram.

Kerala

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	19.08.2023	460	20.44
2	M ₂₀	19.08.2023	450	20.00
3	M ₂₀	19.08.2023	450	20.00

Test conducted by:
Verified by:

Signature:
Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17194

No. T5/922/2021-22/RNK-TVPM

Date: 25.09.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Construction of Mini Indoor Stadium at Meenara Manickal GP,

Amount:1416/-

Invoice No. 4152

Invoice Date: 25.09.2023

To The Chief Engineer

Kerala

Sports Foundation ,Thiruvananthapuram.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
4	M ₂₀	28.08.2023	400	17.78
5	M ₂₀	28.08.2023	370	16.44
6	M ₂₀	28.08.2023	380	16.89

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17195

No. T5/922/2021-22/RNK-TVPM

Date: 25.09.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Construction of Mini Indoor Stadium at Meenara Manickal GP,

Amount:1416/-

Invoice No. 4152

Invoice Date: 25.09.2023

To The Chief Engineer

Kerala

Sports Foundation ,Thiruvananthapuram.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
7	M ₂₀	31.08.2023	530	23.56
8	M ₂₀	31.08.2023	500	22.22
9	M ₂₀	31.08.2023	520	23.11

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer