



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17087

Date: 24.08.2023

Ref:- Your request letter dtd.24.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Amount:1416/-	Invoice No. 4047	Invoice Date: 24.08.2023
---------------	------------------	--------------------------

To M/s Cordial Homes Private Litmited.  
Cordial Layam.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
3	M <sub>25</sub>	27.07.2023	580	25.78
4	M <sub>25</sub>	27.07.2023	600	26.67
5	M <sub>25</sub>	27.07.2023	580	25.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17088

Date: 24.08.2023

Ref:- Your request letter No.E1/12778/23 dtd.23.08.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:

Project No.177/24 Kairaly Kunnimukal road retarring.

Amount:1416/-	Invoice No. 4044	Invoice Date: 24.08.2023
---------------	------------------	--------------------------

To The Assistant Engineer  
& EW Section.

LID

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
1	M <sub>15</sub>	16.08.2023	660	29.33
2	M <sub>15</sub>	16.08.2023	720	32.00
3	M <sub>15</sub>	16.08.2023	650	28.89

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17089

Date: 24.08.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Amount:1416/-	Invoice No. 4045	Invoice Date: 24.08.2023
---------------	------------------	--------------------------

To M/s Cordial Homes Private Limited.  
Cordial Paradise, Poojapura.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
TF I	M <sub>25</sub>	25.07.2023	660	29.33
TF I	M <sub>25</sub>	25.07.2023	700	31.11
TF I	M <sub>25</sub>	25.07.2023	640	28.44

Test conducted by:  
Verified by:

Signature:  
Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17090

Date: 24.08.2023

Ref:- Your request letter 24.08.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Amount:1416/-	Invoice No. 4045	Invoice Date: 24.08.2023
---------------	------------------	--------------------------

To M/s Cordial Homes Private Limited.  
Cordial Paradise, Poojapura.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
SF to TF CLM	M <sub>30</sub>	26.07.2023	680	30.22
SF to TF CLM	M <sub>30</sub>	26.07.2023	700	31.11
SF to TF CLM	M <sub>30</sub>	26.07.2023	640	28.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17092

Date: 24.08.2023

Ref:- Your request letter 24.08.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Amount:1416/-	Invoice No. 4046	Invoice Date: 24.08.2023
---------------	------------------	--------------------------

To M/s Cordial Homes Private Limited.  
Cordial Dev Kazhakoottam.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
Pile	M <sub>30</sub>	16.08.2023	650	28.89
Pile	M <sub>30</sub>	16.08.2023	600	26.67
Pile	M <sub>30</sub>	16.08.2023	720	32.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17093

Date: 24.08.2023

Ref:- Your request letter 21.08.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Ambedkar Settlement Colony at Attingal. Kadampravaram(Retaining wall).

Amount:1416/-	Invoice No. 4009	Invoice Date: 21.08.2023
---------------	------------------	--------------------------

To The Regional Engineer  
Regional Office, Vattiyorkavu.

Date of testing:24.08.2023

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
I	M <sub>20</sub>	17.08.2023	400	17.78
II	M <sub>20</sub>	17.08.2023	410	18.22
III	M <sub>20</sub>	17.08.2023	430	19.11

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY  
CPT CAMPUS, VATTIYOORKAVU  
THIRUVANANTHAPURAM-695013  
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17084

Date: 23.08.2023

Ref:- Your request letter

Testing of: Concrete cube supplied for testing compressive strength.

Project:

Plinth Beam Phase 2

Amount:472/-	Invoice No. 4035	Invoice Date: 23.08.2023
--------------	------------------	--------------------------

To Mr.Jose

Architect,Thakaraparambu Site.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
1	M <sub>25</sub>	16.08.2023	680	30.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer