



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17183
Date: 20.09.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Cordial Deepam.

Amount:1416/-	Invoice No. 4140	Invoice Date:20.09.2023
---------------	------------------	-------------------------

To M/s Cordial Homes Private Limited.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	08.09.2023	550	24.44
2	M ₂₅	08.09.2023	480	21.33
3	M ₂₅	08.09.2023	490	21.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17184
Date: 20.09.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Cordial Deepam.

Amount:1416/-	Invoice No. 4140	Invoice Date:20.09.2023
---------------	------------------	-------------------------

To M/s Cordial Homes Private Limited.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₃₀	10.09.2023	500	22.22
2	M ₃₀	10.09.2023	670	29.78
3	M ₃₀	10.09.2023	580	25.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer