



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17224

No. T5/922/2021-22/RNK-TVPM

Date: 07.10.2023

Ref:- Your request letter dtd.07.10.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Amount:1416/-	Invoice No. 4199	Invoice Date: 07.10.2023
---------------	------------------	--------------------------

To M/s Cordial Homes (P) Ltd.

Cordial Paradise.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
5th III	M ₂₅	05.09.2023	750	33.33
5th III	M ₂₅	05.09.2023	840	37.33
5th III	M ₂₅	05.09.2023	760	33.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17225

No. T5/922/2021-22/RNK-TVPM

Date: 07.10.2023

Ref:- Your request letter dtd.07.10.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Amount:1416/-	Invoice No. 4199	Invoice Date: 07.10.2023
---------------	------------------	--------------------------

To M/s Cordial Homes (P) Ltd.
Cordial Paradise,Poojappura.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
6th I	M ₂₅	09.09.2023	600	26.67
6th I	M ₂₅	09.09.2023	700	31.11
6th I	M ₂₅	09.09.2023	580	25.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer