



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17313

No. T5/922/2021-22/RNK-TVPM

Date: 07.11.2023

Ref:- Your request letter no.SCTL/PRJ/208/2019/6151/8135 dtd.06.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Project:Construction of Multi level car parking A block.

Amount:1416/-	Invoice No. 4307	Invoice Date: 07.11.2023
---------------	------------------	--------------------------

To Nishitha KS
Senior Manager (PMM),
Smartcity Thiruvananthapuram Limited.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
RW 22	M ₃₀	07.10.2023	1080	48.00
RW 22	M ₃₀	07.10.2023	1320	58.67
RW 22	M ₃₀	07.10.2023	980	43.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17314

No. T5/922/2021-22/RNK-TVPM

Date: 07.11.2023

Ref:- Your request letter dtd.07.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Project:Pjt no.267 Kuttankuthi Manjakkode footpath concreting.

Amount:472/-

Invoice No. 4308

Invoice Date: 07.11.2023

To The Assistant Engineer

LSGD Section, Athiyannoor Grama Panchayath.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	31.10.2023	330	14.67

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17315

No. T5/922/2021-22/RNK-TVPM

Date: 07.11.2023

Ref:- Your request letter dtd.07.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Project:Pjt no.276 Pjt no.276 Thongal CSI market road in ward 13.

Amount:472/-	Invoice No. 4308	Invoice Date: 07.11.2023
--------------	------------------	--------------------------

To The Assistant Engineer
LSGD Section, Athiyannoor Grama Panchayath.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₂₀	31.10.2023	310	13.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17316

No. T5/922/2021-22/RNK-TVPM

Date: 07.11.2023

Ref:- Your request letter dtd.07.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Project:Pjt no.259 Kallil Bhaskar Nagar Channel bund road..

Amount:472/-

Invoice No. 4308

Invoice Date: 07.11.2023

To The Assistant Engineer

LSGD Section, Athiyannoor Grama Panchayath.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₂₀	31.10.2023	310	13.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17317

No. T5/922/2021-22/RNK-TVPM

Date: 07.11.2023

Ref:- Your request letter dtd.07.11.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Pjt no.125 Vellamkulam Chemmannuvila Deshabhimani road.

Amount:472/-	Invoice No. 4308	Invoice Date: 07.11.2023
--------------	------------------	--------------------------

To The Assistant Engineer

LSGD Section, Athiyanoor Grama Panchayath.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	31.10.2023	320	14.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer