



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17234

No. T5/922/2021-22/RNK-TVPM

Date: 13.10.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Amount:1416/-	Invoice No. 4215	Invoice Date: 13.10.2023
---------------	------------------	--------------------------

To M/s Cordial Homes Private Limited .
Cordial Deepam.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₂₅	05.10.2023	400	17.78
2	M ₂₅	05.10.2023	420	18.67
3	M ₂₅	05.10.2023	400	17.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17235

No. T5/922/2021-22/RNK-TVPM

Date: 13.10.2023

Ref:- Your request letter no.AEXO/Nirmithi/cube/13.10.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Construction of "Arcon Exotica" Near Kims.

Amount:1416/-	Invoice No. 4218	Invoice Date: 13.10.2023
---------------	------------------	--------------------------

To M/s Arcon Home Builders Private Limited.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
A1	M ₃₀	15.09.2023	590	26.22
A1	M ₃₀	15.09.2023	560	24.89
A1	M ₃₀	15.09.2023	580	25.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17236

No. T5/922/2021-22/RNK-TVPM

Date: 13.10.2023

Ref:- Your request letter no.SCTL/PRJ/217/2019/MUP/7996 Dtd.12.10.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Project:Construction of Redevelopment of Palayam Market for Smartcity.

Amount:1416/-	Invoice No. 4218	Invoice Date: 13.10.2023
---------------	------------------	--------------------------

To M/s Smartcity Thiruvananthapuram Limited.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
ST1	M ₃₀	05.10.2023	460	20.44
ST1	M ₃₀	05.10.2023	450	20.00
ST1	M ₃₀	05.10.2023	470	20.89

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17237

No. T5/922/2021-22/RNK-TVPM

Date: 13.10.2023

Ref:- Your request letter no.QA/SFS/008/92 dtd 13.10.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Project: SFS AMBER Green Block - 9th floor column

Amount:1416/-	Invoice No. 4221	Invoice Date: 13.10.2023
---------------	------------------	--------------------------

To The Senior Manager(QA)

Skyline Foundation & Structures (P) LTD.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₄₅	05.10.2023	850	37.78
2	M ₄₅	05.10.2023	900	40.00
3	M ₄₅	05.10.2023	800	35.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer