



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17345

No. T5/922/2021-22/RNK-TVPM

Date: 17.11.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.
KL-KLLM- ENB-0083, Uliyakovil.

Project:I-

Amount:1416/-	Invoice No. 4346	Invoice Date: 17.11.2023
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrastructure Pvt. Ltd .

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
KLLM-0083	M ₂₀	09.11.2023	460	20.44
KLLM-0083	M ₂₀	09.11.2023	500	22.22
KLLM-0083	M ₂₀	09.11.2023	480	21.33

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17346

No. T5/922/2021-22/RNK-TVPM

Date: 17.11.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.
KL-KLLM- ENB-0083, Uliyakovil.

Project:I-

Amount:1416/-	Invoice No. 4346	Invoice Date: 17.11.2023
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrastructure Pvt. Ltd .

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
KLLM-0083	M ₂₀	10.11.2023	410	18.22
KLLM-0083	M ₂₀	10.11.2023	400	17.78
KLLM-0083	M ₂₀	10.11.2023	410	18.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17347

No. T5/922/2021-22/RNK-TVPM

Date: 17.11.2023

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.
NNKR- ENB-9207, Parakkottam.

Project:I-

Amount:1416/-	Invoice No. 4346	Invoice Date: 17.11.2023
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrastructure Pvt. Ltd .

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
KLLM-0083	M ₂₀	21.10.2023	470	20.89
KLLM-0083	M ₂₀	21.10.2023	520	23.11
KLLM-0083	M ₂₀	21.10.2023	480	21.33

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17348

No. T5/922/2021-22/RNK-TVPM

Date: 17.11.2023

Ref:- Your request letter no.850/SIPK-TVM-GH II/2023 dtd.17.11.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strenght.

Project:DR.GOVINDAN'S HOSPITAL-PHASE II, VANCHIYOOR.

2nd

floor roof slab.

Amount:1416/-	Invoice No. 4347	Invoice Date: 17.11.2023
---------------	------------------	--------------------------

To M/s SI Property (Kerala) Private Limited .

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₂₀	10.11.2023	370	16.44
2	M ₂₀	10.11.2023	380	16.89
3	M ₂₀	10.11.2023	380	16.89

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer