



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17475

No. T5/922/2021-22/RNK-TVPM

Date: 29.12.2023

Ref:- Your request letter no.SCTL/PRJ/210/219/PMM/8397 dtd.29.12.2023.

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Smart City roads - Road ID 27 Utility Duct Raft concreting.

Amount:1416/-	Invoice No. 4559	Invoice Date: 29.12.2023
---------------	------------------	--------------------------

To Smart City Thiruvananthapuram Ltd(SCTL).

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	30.11.2023	830	36.89
2	M ₂₅	30.11.2023	620	27.56
3	M ₂₅	30.11.2023	700	31.11

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer