



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17427

No. T5/922/2021-22/RNK-TVPM

Date: 13.12.2023

Ref:- Your request letter 13.12.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Hotel lemon tree

| | | |
|---------------|------------------|--------------------------|
| Amount:1416/- | Invoice No. 4447 | Invoice Date: 13.12.2023 |
|---------------|------------------|--------------------------|

To The Project Manager
AR Vista Pvt Ltd.
Thycaud, Trivandrum.

TEST RESULTS

| Identification of the cube | Mix | Date of casting | Maximum load taken (KN) | Compressive strength (N/mm ²) |
|----------------------------|-----------------|-----------------|-------------------------|---|
| 1 | M ₄₀ | 28.11.2023 | 1020 | 45.33 |
| 2 | M ₄₀ | 28.11.2023 | 1010 | 44.89 |
| 3 | M ₄₀ | 28.11.2023 | 980 | 43.56 |

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer