



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17547

No. T5/922/2021-22/RNK-TVPM

Date: 19.01.2024

Ref:- Your request letter dtd 19.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Artech MARVEL

Element : Pile cap 9 P90 (Grid A25/17)

Amount:1416/-	Invoice No. 4638	Invoice Date: 19.01.2024
---------------	------------------	--------------------------

To The DGM - Projects
Realtors Private Limited.

Artech

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	M ₃₀	12.01.2024	860	38.22
II	M ₃₀	12.01.2024	870	38.67
III	M ₃₀	12.01.2024	860	38.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17548

No. T5/922/2021-22/RNK-TVPM

Date: 19.01.2024

Ref:- Your request letter dtd 19.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Arcon ELITE, Pippinmoodu

Amount:1416/-	Invoice No. 4637	Invoice Date: 19.01.2024
---------------	------------------	--------------------------

To M/s Arcon Home Builders (P) LTD

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	M ₃₀	12.01.2024	610	27.11
II	M ₃₀	12.01.2024	610	27.11
III	M ₃₀	12.01.2024	550	24.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17549

No. T5/922/2021-22/RNK-TVPM

Date: 19.01.2024

Ref:- Your request letter dtd 19.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Amount:1416/-	Invoice No. 4639	Invoice Date: 19.01.2024
---------------	------------------	--------------------------

To M/s Cordial Homes (P) LTD

Cordial Achutham

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
M ₃₀	M ₃₀	08.01.2024	610	27.11
M ₃₀	M ₃₀	08.01.2024	610	27.11
M ₃₀	M ₃₀	08.01.2024	620	27.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17550

No. T5/922/2021-22/RNK-TVPM

Date: 19.01.2024

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Construction of drain and slab near RC Junction in Kunnukuzhy ward.

Amount:1416/-	Invoice No. 4630	Invoice Date: 17.01.2024
---------------	------------------	--------------------------

To The Assistant Engineer
EW, Municipal Corporation

LID &

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	M ₂₀	12.01.2024	430	19.11
II	M ₂₀	12.01.2024	420	18.67
III	M ₂₀	12.01.2024	420	18.67

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer