



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17557

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter No. E1/15741/23 dtd.25.01.24

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Prj.no.202/24 Enthikunnu Poovathoor Kaitharakkonam road concrete.

Amount:1416/-	Invoice No. 4655	Invoice Date: 29.01.2024
---------------	------------------	--------------------------

To The Assistant Engineer
LID & EW ,
Nedumangad Municipality.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₁₅	25.01.2024	180	8.00
2	M ₁₅	25.01.2024	230	10.22
3	M ₁₅	25.01.2024	190	8.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17558

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter No.APH/Nirmithi/cube/27.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Piling construction(P-70) of "ARCON PLATINUM HEIGHTS" at Chakai.

Date of testing: 27.01.2024

Amount:1416/-

Invoice No. 4650

Invoice Date: 27.01.2024

To M/s Arcon Home Builders Private Limited

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
A-1	M ₂₅	19.01.2024	450	20.00
A-2	M ₂₅	19.01.2024	600	26.67
A-3	M ₂₅	19.01.2024	460	20.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17559

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter No.1/AE/LSGD/PLM/2023-24 dtd.05.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: TVPM DP 2022-23 Manical Pallipichimangalam Thenguvila Kannara road
retarring side wall construction - Pro.no.1112/23.

Date of testing: 27.01.2024

Amount:472/-

Invoice No. 4651

Invoice Date: 27.01.2024

To The Assistant Engineer
LSGD (LID & EW) Section,
Pullampara GP

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	29.12.2023	510	22.67

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17560

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter No.QA/SFS/008/135 dtd.27.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: SFS AMBER Green Block - 14th floor slab and beam.

Date of testing: 27.01.2024

Amount:1416/-

Invoice No. 4653

Invoice Date: 27.01.2024

To M/s Skyline Foundation & structures (P) Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₃₀	28.12.2023	690	30.67
2	M ₃₀	28.12.2023	750	33.33
3	M ₃₀	28.12.2023	800	35.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17561

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter No.QA/SFS/008/134 dtd.27.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: SFS AMBER Green Block - Terrace floor slab and beam.

Date of testing: 27.01.2024

Amount:1416/-

Invoice No. 4653

Invoice Date: 27.01.2024

To M/s Skyline Foundation & structures (P) Ltd.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₃₀	29.12.2023	1000	44.44
2	M ₃₀	29.12.2023	850	37.78
3	M ₃₀	29.12.2023	900	40.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17562

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Amount:472/-	Invoice No. 4654	Invoice Date: 27.01.2024
--------------	------------------	--------------------------

To Mr. Jose
Thakaraparamb site

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	30.12.2023	580	25.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17563

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter No.SCTL/PRJ/210/2019/PMM/8527

Testing of: 6 no's of concrete cube supplied for testing compressive strength.

Project: Smartcity roads - road ID 100, I-Drain Raft concreting, II - Drain wall

Date of testing: 27.01.2024

Amount:2832/-

Invoice No. 4652

Invoice Date: 27.01.2024

To The Manager - Contrats & Projects

Smart City Thiruvananthapuram LTD

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm2)
1	M ₂₀	18.01.2023	400	17.78
2	M ₂₀	18.01.2023	440	19.56
3	M ₂₀	18.01.2023	400	17.78
4	M ₂₀	20.01.2023	430	19.11
5	M ₂₀	20.01.2023	410	18.22
6	M ₂₀	20.01.2023	410	18.22

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17564

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter No. 2/AE/PVCL/2022-23 dtd.24.01.24

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Chamavila Puliyanchirakuzhi road side wall construction.

Amount:1416/-	Invoice No. 4656	Invoice Date: 29.01.2024
---------------	------------------	--------------------------

To The Assistant Engineer
LID & EW ,
Poovachal Grama Panchayath.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₁₅	16.01.2024	16	7.11
2	M ₁₅	16.01.2024	180	8.00
3	M ₁₅	16.01.2024	160	7.11

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17565

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: I-KL-NNKR-ENB-9206, Uchakkada.

Amount:1416/-

Invoice No. 4657

Invoice Date: 29.01.2024

To M/s Karakkattil Projects & Infrastructure (P) LTD.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
NNKR 9206	M ₂₀	18.01.2024	420	18.67
NNKR 9206	M ₂₀	18.01.2024	410	18.22
NNKR 9206	M ₂₀	18.01.2024	440	19.56

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17566

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Amount:1416/-	Invoice No. 4657	Invoice Date: 29.01.2024
---------------	------------------	--------------------------

To M/s Karakkattil Projects & Infrastructure (P) LTD.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
NNKR 9206	M ₂₀	20.01.2024	360	16.00
NNKR 9206	M ₂₀	20.01.2024	600	26.67
NNKR 9206	M ₂₀	20.01.2024	380	16.89

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17567

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter No.SCTL/PRJ/210/2019/PMM/8527 dtd.24.01.24

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Smart City roads - Road ID 100, Drain Raft & wall

Amount:1416/-

Invoice No. 4659

Invoice Date: 29.01.2024

To The Manager - Contracts & Projects
Smart City thiruvananthapuram LTD (SCTL)

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	22.01.2024	460	20.44
2	M ₂₀	22.01.2024	580	25.78
3	M ₂₀	22.01.2024	580	25.78

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

NO:17569

No. T5/922/2021-22/RNK-TVPM

Date: 29.01.2024

Ref:- Your request letter dtd.29.01.24

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Amount:1416/-	Invoice No. 4658	Invoice Date: 29.01.2024
---------------	------------------	--------------------------

To M/s Cordial Homes (P) LTD
Cordial Paradise

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	29.12.2023	580	25.78
2	M ₂₅	29.12.2023	580	25.78
3	M ₂₅	29.12.2023	600	26.67

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer