



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17476

No. T5/922/2021-22/RNK-TVPM

Date: 01.01.2024

Ref:- Your request letter dtd.01.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Amount:1416/-	Invoice No. 4561	Invoice Date: 01.01.2024
---------------	------------------	--------------------------

To M/s Cordial Homes Private Limited
Cordial Paradise.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₅	04.12.2023	300	13.33
2	M ₂₅	04.12.2023	310	13.78
3	M ₂₅	04.12.2023	300	13.33

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17477

No. T5/922/2021-22/RNK-TVPM

Date: 01.01.2024

Ref:- Your request letter dtd.29.12.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Canara Bank RSETI, Kottarakkara, Kollam.

Amount:4248/-

Invoice No. 4562

Invoice Date: 01.01.2024

To M/s KCR INFRA

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₂₀	27.11.2023	650	28.89
2	M ₂₀	27.11.2023	650	28.89
3	M ₂₀	27.11.2023	630	28.00
4	M ₂₀	27.11.2023	730	32.44
5	M ₂₀	27.11.2023	640	28.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17478

No. T5/922/2021-22/RNK-TVPM

Date: 01.01.2024

Ref:- Your request letter dtd.29.12.2023

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Canara Bank RSETI, Kottarakkara, Kollam.

Amount:4248/-	Invoice No. 4562	Invoice Date: 01.01.2024
---------------	------------------	--------------------------

To M/s KCR INFRA

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
6	M ₂₀	27.11.2023	730	32.44
7	M ₂₀	27.11.2023	730	32.44
8	M ₂₀	27.11.2023	610	27.11
9	M ₂₀	27.11.2023	610	27.11

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17479

No. T5/922/2021-22/RNK-TVPM

Date: 01.01.2024

Ref:- Your request letter no.QA/SFS/008/129 dtd.01.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: SFS AMBER Green Block

13th floor slab and beam.

Amount:1416/-

Invoice No. 4563

Invoice Date: 01.01.2024

To M/s Skyline Foundation & Structures (P) Ltd.

TEST RESULTS

Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
1	M ₃₀	02.12.2023	720	32.00
2	M ₃₀	02.12.2023	690	30.67
3	M ₃₀	02.12.2023	840	37.33

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17480

No. T5/922/2021-22/RNK-TVPM

Date: 01.01.2024

Ref:- Your request letter dtd.01.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project:Stories in the Sky, Akkulam.

Column and slab.

Amount:1416/-	Invoice No. 4564	Invoice Date: 01.01.2024
---------------	------------------	--------------------------

To M/s iCloud Home Pvt Ltd.

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
cube 1	M ₃₅	02.12.2023	820	36.44
cube 2	M ₃₅	02.12.2023	1290	57.33
cube 3	M ₃₅	02.12.2023	840	37.33

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer