



KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY
CPT CAMPUS, VATTIYOORKAVU
THIRUVANANTHAPURAM-695013
PHONE No. 0471 - 2362229

No. T5/922/2021-22/RNK-TVPM

NO:17604

Date: 06.02.2024

Ref:- Your request letter SCTL/PRJ/210/2019/PMM/8559 dtd.30.01.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Smart roads - Road ID-100

Amount:1416/-

Invoice No. 4693

Invoice Date: 06.02.2024

To The Manager - Contracts & Projects
Smart City Thiruvananthapuram LTD (SCTL)

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm ²)
I	M ₂₀	29.01.2024	620	27.56
II	M ₂₀	29.01.2024	550	24.44
III	M ₂₀	29.01.2024	640	28.44

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer