



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17616

No. T5/922/2021-22/RNK-TVPM

Date: 12.02.2024

Ref:- Your request letter No.09/AE/LID & EW/MKL/2023-24

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Anganamvila Parambuvara road concreting.

Amount:1416/-	Invoice No. 4696	Invoice Date: 07.02.2024
---------------	------------------	--------------------------

To The Assistant Engineer  
& EW Section  
Grama Panchayath

LID  
Manickal

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
I	M <sub>20</sub>	27.01.2024	680	30.22
II	M <sub>20</sub>	27.01.2024	680	30.22
III	M <sub>20</sub>	27.01.2024	660	29.33

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer



# KERALA STATE NIRMITHI KENDRA

NIRMITHI TESTING LABORATORY

CPT CAMPUS, VATTIYOORKAVU

THIRUVANANTHAPURAM-695013

PHONE No. 0471 - 2362229

NO:17617

No. T5/922/2021-22/RNK-TVPM

Date: 12.02.2024

Ref:- Your request letter dtd.12.02.2024

Testing of: 3 no's of concrete cube supplied for testing compressive strength.

Project: Pappanamcode road concreting

Amount:1416/-	Invoice No. 4717	Invoice Date: 12.02.2024
---------------	------------------	--------------------------

To The Assistant Engineer  
LSGD, Peringamala Grama Panchayath

TEST RESULTS				
Identification of the cube	Mix	Date of casting	Maximum load taken (KN)	Compressive strength (N/mm <sup>2</sup> )
I	M <sub>20</sub>	24.01.2024	520	23.11
II	M <sub>20</sub>	24.01.2024	580	25.78
III	M <sub>20</sub>	24.01.2024	540	24.00

Test conducted by:

Signature:

Verified by:

Signature:

COUNTER SIGNED AND ISSUED



Office Seal

Regional Engineer